

List of Figures

2.1	Convergence properties of CNR on IEEE 30 Bus system	24
2.2	Convergence properties of CINR on IEEE 30 Bus system	24
2.3	Convergence properties of Rev-CINR on IEEE 30 Bus system	25
2.4	Convergence properties of NR-CINR on IEEE 30 Bus system	25
2.5	Convergence properties of Mod-CINR on IEEE 30 Bus system	25
3.1	Flow chart of Particle Swarm Optimization	41
4.1	Flow chart of re-phasing using PSO.	80
4.2	Test system showing line type(#) and line length (ft.).	81
4.3	System voltages for base case	82
4.4	System voltages after re-phasing	83
4.5	Comparison of MVA flows in each phase at the main substation for base case and re-phased case using PSO, GA and BO.	84
4.6	Comparison of Sequence Currents and %RMSI for base case and re-phased case using PSO, GA and BO	85
4.7	Base case phase currents and MVA intake at main sub-station for the system	86
4.8	Re-phased phase currents and MVA intake at main sub-station. . .	87
4.9	Base case sequence currents at main sub-station for the system. . .	88
4.10	Re-phased sequence currents at main sub-station.	89
4.11	Minimum system voltages for the daily load curve for the base case.	90
4.12	Minimum system voltages for the daily load curve for the re-phased system.	91

4.13	RMSI values for base case and re-phased case at main sub-station.	92
5.1	Test system showing line type(#) and line length (ft.).	97
5.2	Active load for all the buses at phase-a for 24 hours.	99
5.3	Active load for all the buses at phase-b for 24 hours.	100
5.4	Active load for all the buses at phase-c for 24 hours.	101
5.5	Reactive load for all the buses at phase-a for 24 hours.	102
5.6	Reactive load for all the buses at phase-b for 24 hours.	103
5.7	Reactive load for all the buses at phase-c for 24 hours.	104
5.8	Bus voltages without and with DGs. V_a, V_b, V_c indicate bus voltages without DGs. V_a^*, V_b^*, V_c^* indicate bus voltages with DGs.	108
5.9	Hourly positive-, zero-, negative-sequence currents without and with DGs. $I_0, I_1,$ and I_2 indicate sequence currents for the case when DGs are not placed. $I_0^*, I_1^*,$ and I_2^* indicate sequence currents for the case when DGs are placed.	109
5.10	Hourly phase currents without and with DGs. $I_a, I_b,$ and I_c indicate phase currents for the case when DGs are not placed. $I_a^*, I_b^*,$ and I_c^* indicate phase currents for the case when DGs are placed.	110
5.11	Minimum of the all bus Voltages without DGs and with DGs for 24 hour. V_{min} and V_{min}^* indicate the minimum bus voltage in case of Without DGs and with DGs respectively.	111
5.12	Total active and reactive power line loses for 24-hours. P_{loss} and Q_{loss} indicate total active and reactive line losses for the case when DGs are not placed. P_{loss}^* and Q_{loss}^* indicate total active and reactive power line loss for the case when DGs are placed.	112
5.13	Phase Utilization Index at main feeder for 24 hours. PUI and PUI^* indicates the phase utilization index in case of without DGs and with DGs respectively.	113
7.1	VVVF system generator model using DDS	123
7.2	DTC simulink model	124
7.3	DTC System generator model	124